

SAFE DRINKING WATER CERTIFICATE

Ref No.: ARRA/LAB/25-26
63

Date: 06 / 04 / 2026

It is certified that G.D. GOENKA PUBLIC SCHOOL, situated at Salempur Road, Near Mahuli Pul, Arrah, District-Bhojpur, Bihar – 802312 has safe drinking water facilities for the students and staff members of the institution.

The drinking water supplied in the school premises has been tested and found fit for human consumption as per the prescribed standards.

This certificate is issued for the purpose of compliance with the requirements of CBSE, New Delhi and other concerned authorities.

Place: Arrah

Date: _ / _ / 2026

Signature: शुभंकर
Name: शुभंकर कुमार विश्वास
Designation: (अनुसंधान) शोध सहायक
Office Seal: Research Assistant

DLWQTL,
P.H. Div, Arra

To

G.D. Goenka Public School, Arrah
Near Mahuli Pul, Arrah, Bhojpur

(Name & address of the institution)

District Name :Bhojpur
Sample Collected By : Self

Division Name: P.H. Division, Ara

Government of Bihar
Public Health Engineering Department
Monthly Water Quality Monitoring Report

Date of Sampling :- 18-03-2026
Date of Testing :- 06-04-2026

Sample Collected By : Self					Division Name: P.H. Division, Ara					Date of Sampling :- 18-03-2026												
					Date of Testing :- 06-04-2026																	
S	Block	Panchayat	Village	Location of Source	Ward No.	Parameters																Remarks
						pH	Turb	EC	TDS	TH	Ca	Mg	Cl	Alka	Fe	NO ₃	SO ₄	F	As	Total Coli		
1	ARA	-		WATER SAMPLE OF G.D.GOENKA PUBLIC SCHOOL ARA	-	7.613	0.2	595	386	220	67.33	12.63	79.96	280	0.13	NT	NT	NT	<0.001	-ve	Safe	
Permissible Limit in absence of alternative source						6.5-8.5	1	-	500	200	75	30	250	200	1	45	200	1	0.01	-		
						NR	5	-	2000	600	200	100	1000	500	NR	NR	400	1.5	NR	-		

*NT = Not Tested. BDL=Below Detection Limit

*NT = Not Tested, BDL=Below Detection Limit


06/04/2026
Research Assistant
(Chemist)
P.H. Division, Ara
Research Assistant
DLWQTL,
P.H. Div. Ara